

Main Features

- The self-signed OPC UA client certificates generated by the ioHandler for OPC-UA shipped with 2.15.5 were invalid and thus not accepted by some PLCs. This issue has been resolved.
- If you have previously installed WebIQ 2.15.5 and upgrade to WebIQ 2.15.6 you have to manually delete the client certificate files:

Windows

- C:\ProgramData\WebIQ\io-shared\ioHandlerOPC\client.der
- C:\ProgramData\WebIQ\io-shared\ioHandlerOPC\client.pem

Linux

- /var/lib/webiq/io-shared/ioHandlerOPC/client.der
- /var/lib/webiq/io-shared/ioHandlerOPC/client.pem

If you have previously installed WebIQ < 2.15.5 you do not need to and should not delete these files!

Please note that when you delete these files the newly generated client certificate has to be trusted usually on the OPC UA server!

WebIQ Server

- WEBIQ-4049 Fix: ioHandlerOPC: Generated client certificates are not accepted by some OPC UA servers (introduced in 2.15.5)